# **Energy performance certificate (EPC)**

Greytown House 221-227 High Street ORPINGTON BR6 0NZ Energy rating

Valid until:	30 April 2033
Certificate number:	0249-1202-8307-9885- 2404


Property type C	Offices and Workshop Businesses
Total floor area 5	587 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

### **Energy rating and score**

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built	14 A
If typical of the existing stock	55 C

## Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	21.8
Primary energy use (kWh/m2 per year)	178

## **Recommendation report**

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/2190-4984-8070-4205-8225)</u>.

### Who to contact about this certificate

### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Nick Stevenson
Telephone	07736695824
Email	nick@stevenson24.com

### **Contacting the accreditation scheme**

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Quidos Limited
QUID207459
01225 667 570
info@quidos.co.uk
N Stevenson Consultancy
•
The assessor is not related to the owner of the property.
28 April 2023
1 May 2023